

108年飛灰穩定化物採樣檢測分析值

項目	法規值	月份 單位	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月
			Org-Hg	-	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hg	0.2	mg/L	ND	ND	ND	ND	ND	0.0011	0.002	ND	ND	ND	ND	ND
Pb	5	mg/L	ND	ND	0.023	0.018	ND	0.02	0.027	0.02	0.019	0.022	ND	ND
Cd	1	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01	ND
Cr	5	mg/L	ND	ND	ND	ND	ND	ND	0.029	ND	ND	ND	ND	ND
Cr ⁺⁶	2.5	mg/L	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	ND	< 0.03	ND	< 0.02	< 0.02	< 0.02	< 0.02
Cu	15	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Zn	-	mg/L	0.088	0.097	0.054	0.085	0.069	0.107	0.081	0.091	0.128	0.125	0.088	0.08
As	5	mg/L	ND	0.043	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
單軸抗壓 強度	>10	kgf/cm ²	27	35	30	27	46	35	45	18	58	25	81	60
pH	-	-	11.97	12.38	12.02	11.87	12.08	11.88	11.90	11.78	11.8	11.82	11.78	12
Se	1	mg/L	ND	0.039	0.075	0.041	ND	0.075	0.085	0.054	ND	ND	0.05	0.041
Ba	100	mg/L	2.09	1.95	1.97	2.10	2.61	2.03	1.66	1.96	1.95	1.53	1.71	1.55
戴奧辛	1	ngI-TEQ/g	0.233	0.312	0.208	0.207	0.151	0.165	0.130	0.147	0.096	0.109	0.155	0.147